

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PH/JKR/428

Dated: 01/03/2024

It is certified that an inspection team headed by Bichitra Kumar Pahan, JE

(Name of Officers with designation) from Jajpur Road PHED

inspected the Drinking water & Sanitation System

(Name & Address of the school) on 22/02/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RWS/JKR/205 dated 21/2/2024

of RWS, S.S. Div. Lab, Kusunpur (PHED Lab) certified that the

Dev International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01/03/2025 (One yr only)

Signature with Seal: P. H. Section

Name: Jajpur Road

Designation: Junior Engineer

Name & Address of the Office / Department: 21/03/2024

To

Dev International School
KUSUNPUR, JAJPUR ROAD

(Name & Address of the Institution) (ODISHA)

pin: 755026

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
Principal
Dev International School
Kusunpur, Jajpur


No. RWS / JJKR / 205

Dated: 02/02/2024

ANALYTICAL REPORT OF WATER SAMPLE TESTED UNDER RWS&S SUBDIVISIONAL LABORATORY, SUKINDA, AT - DANAGADI

SL.N O.	BLOCK	VILLAGE	WARD NO.	HABITATION	PARAMETERS mg/ttr						
					a	b	c	d	e	f	g
					PH	Alkalinity	Hardness	Chloride	Iron	Fluoride	H2s Stripe
1	KORAI	KUSUNPUR	6	DEV INTERNATI ONAL SCHOOL, JAJPUR	7.08	140.00	240.00	25.00	0.00	0.54	Negative


Principal
Dev International School
Kusunpur, Jajpur


Laboratory Assistant
RWS&S Subdivisional Laboratory,